



E.L. Haynes PCS [Georgia Ave] - Lead in Water Test Results



FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
E.L. Haynes PCS [Georgia Ave]	WS-009-001	Food Prep Sink	Basement	In kitchen			WF-022021-009001-03	6/23/2021	FT-FY21-022021-009001-A	<1	FT-FY21-022021-009001-B	<1
E.L. Haynes PCS [Georgia Ave]	WS-009-002	Cooler	Basement	In hallway adjacent to cafeteria	High	Left	WF-022021-009002-03	N/A	FT-FY21-022021-009002-A	Non-Op	FT-FY21-022021-009002-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-003	Cooler	Basement	In hallway adjacent to cafeteria	Low	Right	WF-022021-009003-03	N/A	FT-FY21-022021-009003-A	Non-Op	FT-FY21-022021-009003-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-004	Health Suite	1	In nurse's office room 102			WF-022021-009004-03	6/23/2021	FT-FY21-022021-009004-A	2.6	FT-FY21-022021-009004-B	<1
E.L. Haynes PCS [Georgia Ave]	WS-009-005	Cooler	1	In hallway adjacent to room 102	High	Left	WF-022021-009005-03	N/A	FT-FY21-022021-009005-A	Non-Op	FT-FY21-022021-009005-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-006	Cooler	1	In hallway adjacent to room 102	Low	Right	WF-022021-009006-03	N/A	FT-FY21-022021-009006-A	Non-Op	FT-FY21-022021-009006-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-007	Cooler	2	In hallway adjacent to room 212A	High	Left	WF-022021-009007-03	N/A	FT-FY21-022021-009007-A	Non-Op	FT-FY21-022021-009007-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-008	Cooler	2	In hallway adjacent to room 212A	Low	Right	WF-022021-009008-03	N/A	FT-FY21-022021-009008-A	Non-Op	FT-FY21-022021-009008-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-009	Cooler	3	In hallway adjacent to room 302	High	Left	WF-022021-009009-03	N/A	FT-FY21-022021-009009-A	Non-Op	FT-FY21-022021-009009-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-010	Cooler	3	In hallway adjacent to room 302	Low	Right	WF-022021-009010-03	N/A	FT-FY21-022021-009010-A	Non-Op	FT-FY21-022021-009010-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-011	Break Room	4	In teachers' lounge 408			WF-022021-009011-03	6/23/2021	FT-FY21-022021-009011-A	<1	FT-FY21-022021-009011-B	<1
E.L. Haynes PCS [Georgia Ave]	WS-009-012	Cooler	4	In hallway adjacent to room 402	High	Left	WF-022021-009012-03	N/A	FT-FY21-022021-009012-A	Non-Op	FT-FY21-022021-009012-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-013	Cooler	4	In hallway adjacent to room 402	Low	Right	WF-022021-009013-03	N/A	FT-FY21-022021-009013-A	Non-Op	FT-FY21-022021-009013-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-014	Cooler	5	In hallway adjacent to room 502	High	Left	WF-022021-009014-03	N/A	FT-FY21-022021-009014-A	Non-Op	FT-FY21-022021-009014-B	Non-Op
E.L. Haynes PCS [Georgia Ave]	WS-009-015	Cooler	5	In hallway adjacent to room 502	Low	Right	WF-022021-009015-03	N/A	FT-FY21-022021-009015-A	Non-Op	FT-FY21-022021-009015-B	Non-Op